

Lester, Steve

From: Scott King [SKing@spfwater.com]
Sent: Tuesday, May 20, 2008 4:58 PM
To: Lester, Steve
Subject: 63-32499 Mayfield Townsite Application

Steve,

Thank you for the update. Regarding the wells proposed under the Mayfield Townsite application 63-32499, we estimate water bearing zones ranging from 200 to 1,200 feet below ground level depending on well location and aquifer conditions encountered.

If you have any other questions, please let me know.

Thank you,
Scott

Scott N. King, P.E.
Senior Project Engineer
SPF Water Engineering, LLC
600 East River Park Lane, Suite 105
Boise, Idaho 83706
phone: (208) 383-4140 x209
fax: (208) 383-4156
email: sking@spfwater.com
web page: www.spfwater.com

Water bearing zone 200-1200 ft.