

Idaho Department of Water Resources **REQUEST FOR VARIANCE: IDWR REQUIRED FLOW METER MINIMUM SPACING**

The existing minimum flow meter spacing requirement is: no flow disturbers within three (3) pipe diameters upstream and two (2) pipe diameters downstream as measured from the center of the magnetic or spooled ultrasonic flow meter. A spacing variance will only be considered for systems previously evaluated by either the local Ground Water District or Water District and determined to not have adequate straight pipe section(s) to meet the minimum spacing requirement. *Complete one form for each affected well.*

SECTION I: SITE DETAILS

1. Owner/Operator			2. Well Name			
3. IDWR Site Tag No.	4. Legal Description:	4a. Township	4b.	Range	4c. Section	5. Ground Water District
6. Reporting District (ground	water district, i	irrigation district	t, or c	other entity)	

SECTION II: CONDITIONS FOR POSSIBLE VARIANCE

Variance from the existing installation requirement may be considered if: (choose only one scenario)

	7. The meter manufacturer specifications support meter accuracy of at least plus or minus five percent (+/-5%) in the proposed field installation location.
	Required: Submit a copy of or reference to the manufacturer specification(s) guaranteeing the meter
	will achieve an accuracy of +/- 5% in the proposed field installation location.
	8. Field testing of the installed meter confirms accuracy of at least plus or minus five percent (+/-5%).
	Required: Submit a proposed plan and system location for testing accuracy of the meter after
	installation. (Note: portable meters used for flow testing typically require 10-pipe diameters upstream and 5-pipe diameters
	downstream)

SECTION III: FLOW METER DETAILS

9. Have you consulted with your loca and fully evaluated locations that mig accommodate a properly installed flo	☐ Yes (complete 9a – 9d) ☐ No (consult with your local GWD or WD before submitting this form)		
9a. District Representative Name		9b. District Name	
9c. District Representative Phone Number 9d. District Representa			Email
10. Can the flow meter be installed o	on an underground	mainline?	□ Yes □ No
11. Can the flow meter be installed in a vertical orientation in a "gooseneck" configuration? (This option may require pipe system modification)			□ Yes □ No
12. Can multiple meters be installed discharge assembly?	nultiple meters be installed on distribution lines away from the pump assembly?		
13. Is a flow meter currently installed existing or proposed meter, see 13a	•	vide details of the	□Yes □No
13a. Meter Type (magnetic or ultra-sonic)	13b. Meter Manufact	urer	13c. Meter Model

version 1.0 - updated 7.18.2017			Page 2 of 2
13d. Meter Installation Date	13e. Is the meter operable?	□ Yes □ No	

SECTION VI: SYSTEM DIAGRAMS AND MAPS (Required for all variance requests)

Attach a system description which includes diagrams or photographs of the piping system between the well head and the point where the mainline splits, pipe diameters, fitting descriptions, and distances between disturbers, including pump discharges, valves, chemigation ports, elbows, and/or tees.

If a flow meter is not currently installed, provide a description of the location on the system where you propose to install the flow meter.

SECTION VII: APPLICANT SIGNATURE AND CONTACT INFORMATION

Signature	Print Name	Title (if applicable)	
Mailing Address			
Email Address	Phone Number	Date	
Return this completed an	d signed form to:	IDWR Water Distribution Section PO Box 83720 Boise, ID 83720-0098	

This request must be approved by IDWR before you may use an alternate meter location.