

## ATTACHMENT 1 - BIDDER QUESTIONS

ITB Number 23-03 Well Drilling Services

	ITB Section	ITB Page	Question	Response
1	23-03	3	Sch. of pvc, slot size on screen and are we sand packing	Schedule 40, 0.01-inch slot opening, no sand pack
2	23-03	4	Sch. of pvc, slot size on screen and are we sand packing	Schedule 40, 0.01-inch slot opening, no sand pack
3	23-03	5	Sch. of pvc, slot size on screen and are we sand packing	Schedule 40, 0.01-inch slot opening, no sand pack
4	23-03	8	Sch. of pvc, slot size on screen and are we sand packing	Schedule 40, 0.01-inch slot opening, no sand pack
5	23-03	9	Sch. of pvc, slot size on screen and are we sand packing	Schedule 40, 0.01-inch slot opening, no sand pack
6	23-03	10	Sch. of pvc, slot size on screen and are we sand packing	Schedule 40, 0.01-inch slot opening, no sand pack
7	9.2.1	4	ITB states do not submit items in .pdf format, unless provided otherwise in this ITB.	PDF forms provided with this ITB are allowed.
8			Is a bid bond required?	No.
9			Will awarded bidder be required to produce a performance bond	No.
10			Is a idaho public works license required	No.
11			What is the engineers cost estimate for this project	Due to the competitive bidding process, the budget will not be shared publicly at this time.
12				
13				
14				
15				